

**ATTACHMENT A**  
**CWIS Technology Fact Sheets**

**DESCRIPTION:**

The single-entry, single-exit vertical traveling screens (conventional traveling screens) consist of screen panels mounted on an endless belt; the belt rotates through the water vertically. The screen mechanism consists of the screen, the drive mechanism, and the spray cleaning system. Most of the conventional traveling screens are fitted with 3/8-inch mesh and are designed to screen out and prevent debris from clogging the pump and the condenser tubes. The screen mesh is usually supplied in individual removable panels referred to as “ baskets” or “trays”.

The screen washing system consists of a line of spray nozzles operating at a relatively high pressure of 80 to 120 pounds per square inch (psi). The screens are usually designed to rotate at a single speed. The screens are rotated either at predetermined intervals or when a predetermined differential pressure is reached across the screens based on the amount of debris in the intake waters.

Because of this intermittent operation of the conventional traveling screens, fish can become impinged against the screens during the extended period of time while the screens are stationary and eventually die. When the screens are rotated the fish are removed from the water and then subjected to a high pressure spray; the fish may fall back into the water and become re-impinged or they may be damaged (EPA, 1976, Pagano et al, 1977).

**Conventional Traveling Screen (EPA, 1976)**

**TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

- C The conventional traveling screens are the most common screening device presently used at steam electric power plants. Sixty percent of all the facilities use this technology at their intake structure (EEI, 1993).

**RESEARCH/OPERATION FINDINGS:**

- C The conventional single-entry single screen is the most common device resulting in impacts from entrainment and impingement (Fritz, 1980).

**DESIGN CONSIDERATIONS:**

- C The screens are usually designed structurally to withstand a differential pressure across their face of 4 to 8 feet of water.
- C The recommended normal maximum water velocity through the screen is about 2.5 feet per second (ft/sec). This recommended velocity is where fish protection is not a factor to consider.
- C The screens normally travel at one speed (10 to 12 feet per minute) or two speeds (2.5 to 3 feet per minute and 10 to 12 feet per minute). These speeds can be increased to handle heavy debris load.

**ADVANTAGES:**

- C Conventional traveling screens are a proven "off-the-shelf" technology that is readily available.

**LIMITATIONS:**

- C Impingement and entrainment are both major problems in this unmodified standard screen installation, which is designed for debris removal not fish protection.

**REFERENCES:**

ASCE. Design of Water Intake Structures for Fish Protection. Task Committee on Fish-Handling Capability of Intake Structures of the Committee on Hydraulic Structures of the Hydraulic Division of the American Society of Civil Engineers, New York, NY. 1982.

EEI Power Statistics Database. Prepared by the Utility Data Institute for the Edison Electric Institute. Washington, D.C., 1993.

Fritz, E.S. Cooling Water Intake Screening Devices Used to Reduce Entrainment and Impingement. Topical Briefs: Fish and Wildlife Resources and Electric Power Generation, No. 9. 1980.

Pagano R. and W.H.B. Smith. Recent Developments in Techniques to Protect Aquatic Organisms at the Intakes of Steam-Electric Power Plants. MITRE Corporation Technical Report 7671. November 1977.

U.S. EPA. Development Document for Best Technology Available for the Location, Design, Construction, and Capacity of Cooling Water Intake Structures for Minimizing Adverse Environmental Impact. U.S. Environmental Protection Agency, Effluent Guidelines Division, Office of Water and Hazardous Materials. EPA 440/1-76/015-a. April 1976.

**DESCRIPTION:**

Modified vertical traveling screens are conventional traveling screens fitted with a collection “bucket” beneath the screen panel. This intake screening system is also called a bucket screen, Ristroph screen, or a Surry Type screen. The screens are modified to achieve maximum recovery of impinged fish by maintaining them in water while they are lifted to a release point. The buckets run along the entire width of the screen panels and retain water while in upward motion. At the uppermost point of travel, water drains from the bucket but impinged organisms and debris are retained in the screen panel by a deflector plate. Two material removal systems are often provided instead of the usual single high pressure one. The first uses low-pressure spray that gently washes fish into a recovery trough. The second system uses the typical high-pressure spray that blasts debris into a second trough. Typically, an essential feature of this screening device is continuous operation which keeps impingement times relatively short (Richards, 1977; Mussalli, 1977; Pagano et al., 1977; EPA , 1976).

**Modified Vertical Traveling Screens (White et al, 1976)**

## **TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

Facilities which have tested the screens include: the Surry Power Station in Virginia (White et al, 1976) (the screens have been in operation since 1974), the Madgett Generating Station in , Wisconsin, the Indian Point Nuclear Generating Station Unit 2 in New York, the Kintigh (formerly Somerset) Generating Station in New Jersey, the Bowline Point Generating Station (King et al, 1977), the Roseton Generating Station in New York, the Danskammer Generating Station in New York (King et al, 1977), the Hanford Generating Plant on the Columbia River in Washington (Page et al, 1975; Fritz, 1980), the Salem Generating on the Delaware River in New Jersey, and the Monroe Power Plant on the Raisin River in Michigan.

## **RESEARCH/OPERATION FINDINGS:**

Modified traveling screens have been shown to have good potential for alleviating impingement mortality. Some information is available on initial and long-term survival of impinged fish (EPRI, 1999; ASCE, 1982; Fritz, 1980). Specific research and operation findings are listed below:

- C In 1986, the operator of the Indian Point Station redesigned fish troughs on the Unit 2 intake to enhance survival. Impingement injuries and mortality were reduced from 53 to 9 percent for striped bass, 64 to 14 percent for white perch, 80 to 17 percent for Atlantic tomcod, and 47 to 7 percent for pumpkinseed (EPRI, 1999).
- C The Kintigh Generating Station has modified traveling screens with low pressure sprays and a fish return system. After enhancements to the system in 1989, survivals of generally greater than 80 percent have been observed for rainbow smelt, rock bass, spottail shiner, white bass, white perch, and yellow perch. Gizzard shad survivals have been 54 to 65 percent and alewife survivals have been 15 to 44 percent (EPRI, 1999).
- C Long-term survival testing was conducted at the Hanford Generating Plant on the Columbia River (Page et al, 1975; Fritz, 1980). In this study, 79 to 95 percent of the impinged and collected Chinook salmon fry survived for over 96 hours.
- C Impingement data collected during the 1970s from Dominion Power's Surry Station indicated a 93.8 percent survival rate of all fish impinged. Bay anchovies had the lowest survival rate of 83 percent. The facility has modified Ristroph screens with low pressure wash and fish return systems (EPRI 1999).
- C At the Arthur Kill Station, 2 of 8 screens are modified Ristroph type; the remaining six screens are conventional type. The modified screens have fish collection troughs, low pressure spray washes, fish flap seals, and separate fish collection sluices. 24-hour survival for the unmodified screens averages 15 percent, while the two modified screens have 79 and 92 percent average survival rates (EPRI 1999).

**DESIGN CONSIDERATIONS:**

- C The same design considerations as for Fact Sheet No. 1: Conventional Vertical Traveling Screens apply (ASCE, 1982).

**ADVANTAGES:**

- C Traveling screens are a proven “off-the-shelf” technology that is readily available. An essential feature of such screens is continuous operation during periods where fish are being impinged compared to conventional traveling screens which operate on an intermittent basis

**LIMITATIONS:**

- C The continuous operation can result in undesirable maintenance problems (Mussalli, 1977).
- C Velocity distribution across the face of the screen is generally very poor.
- C Latent mortality can be high, especially where fragile species are present.

**REFERENCES:**

ASCE. Design of Water Intake Structures for Fish Protection. Task Committee on Fish-Handling Capability of Intake Structures of the Committee on Hydraulic Structures of the Hydraulic Division of the American Society of Civil Engineers, New York, NY. 1982.

Electric Power Research Institute (EPRI). Fish Protection at Cooling Water Intakes: Status Report. 1999.

EPRI. Intake Technologies: Research Status. Electric Power Research Institute GS-6293. March 1989.

U.S. EPA. Development Document for Best Technology Available for the Location, design, Construction, and Capacity of Cooling Water Intake Structures for Minimizing Adverse Environmental Impact. Environmental Protection Agency, Effluent Guidelines Division, Office of Water and Hazardous Materials, EPA 440/1-76/015-a. April 1976.

Fritz, E.S. Cooling Water Intake Screening Devices Used to Reduce Entrainment and Impingement. Topical Briefs: Fish and Wildlife Resources and Electric Power Generation, No. 9, 1980.

King, L.R., J.B. Hutchinson, Jr. and T.G. Huggins. "Impingement Survival Studies on White Perch, Striped Bass, and Atlantic Tomcod at Three Hudson Power Plants". In Fourth National Workshop on Entrainment and Impingement, L.D. Jensen (Editor) Ecological Analysts, Inc., Melville, NY. Chicago, December 1977.

Mussalli, Y.G., "Engineering Implications of New Fish Screening Concepts". In Fourth National Workshop on Entrainment and Impingement, L.D. Jensen (Editor). Ecological Analysts, Inc., Melville, N.Y. Chicago, December 1977, pp 367-376.

Pagano, R. and W.H.B. Smith. Recent Developments in Techniques to Protect Aquatic Organisms at the Intakes Steam-Electric Power Plants. MITRE Technical Report 7671. November 1977.

Richards, R.T. "Present Engineering Limitations to the Protection of Fish at Water Intakes". In Fourth National Workshop on Entrainment and Impingement, pp 415-424. L.D. Jensen (Editor). Ecological Analysts, Inc., Melville, N.Y. Chicago, December 1977.

White, J.C. and M.L. Brehmer. "Eighteen-Month Evaluation of the Ristroph Traveling Fish Screens". In Third National Workshop on Entrainment and Impingement. L.D. Jensen (Editor). Ecological Analysts, Inc., Melville, N.Y. 1976.



**DESCRIPTION:**

Inclined traveling screens utilize standard through-flow traveling screens where the screens are set at an angle to the incoming flow as shown in the figure below. Angling the screens improves the fish protection effectiveness of the flush mounted vertical screens since the fish tend to avoid the screen face and move toward the end of the screen line, assisted by a component of the inflow velocity. A fish bypass facility with independently induced flow must be provided. The fish have to be lifted by fish pump, elevator, or conveyor and discharged to a point of safety away from the main water intake (Richards, 1977).

fig : Richards, 4<sup>th</sup> page 419

**Inclined Traveling Screens (Richards, 1977)****TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

Angled screens have been tested/used at the following facilities: the Brayton Point Station Unit 4 in Massachusetts; the San Onofre Station in California; and at power plants on Lake Ontario and the Hudson River (ASCE, 1982; EPRI, 1999).

**RESEARCH/OPERATION FINDINGS:**

- C Angled traveling screens with a fish return system have been used on the intake for Brayton Point Unit 4. Studies from 1984 through 1986 that evaluated the angled screens showed a diversion efficiency of 76 percent with latent survival of 63 percent. Much higher results were observed excluding bay anchovy. Survival efficiency for the major taxa exhibited an extremely wide range, from 0.1 percent for bay anchovy to 97 percent for tautog. Generally, the taxa fell into two groups: a hardy group with efficiency greater than 65 percent and a sensitive group with efficiency less than 25 percent (EPRI, 1999).
- C Southern California Edison at its San Onofre steam power plant had more success with angled louvers than with angled screens. The angled screen was rejected for full-scale use because of the large bypass flow required to yield good guidance efficiencies in the test facility.

**DESIGN CONSIDERATIONS:**

Many variables influence the performance of angled screens. The following recommended preliminary design criteria were developed in the studies for the Lake Ontario and Hudson River intakes (ASCE, 1982):

- C Angle of screen to the waterway: 25 degrees
- C Average velocity of approach in the waterway upstream of the screens: 1 foot per second
- C Ratio of screen velocity to bypass velocity: 1:1
- C Minimum width of bypass opening: 6 inches

**ADVANTAGES:**

- C The fish are guided instead of being impinged.
- C The fish remain in water and are not subject to high pressure rinsing.

**LIMITATIONS:**

- C Higher cost than the conventional traveling screen
- C Angled screens need a stable water elevation.
- C Angled screens require fish handling devices with independently induced flow (Richards, 1977).

## **REFERENCES:**

ASCE. Design of Water Intake Structures for Fish Protection. Task Committee on Fish-Handling Capability of Intake Structures of the Committee on Hydraulic Structures of the Hydraulic Division of the American Society of Civil Engineers, New York, NY. 1982.

Electric Power Research Institute (EPRI). Fish Protection at Cooling Water Intakes: Status Report. 1999.

U.S. EPA. Development Document for Best Technology Available for the Location, Design, Construction, and Capacity of Cooling Water Intake Structures for Minimizing Adverse Environmental Impact. U.S. Environmental Protection Agency, Effluent Guidelines Division, Office of Water and Hazardous Materials. EPA 440/1-76/015-a. April 1976.

Richards, R.T. "Present Engineering Limitations to the Protection of Fish at Water Intakes". In Fourth National Workshop on Entrainment and Impingement, L.D. Jensen (Editor). Ecological Analysts, Inc., Melville, N.Y. Chicago. December 1977. pp 415-424.

**DESCRIPTION:**

Fine mesh screens are used for screening eggs, larvae, and juvenile fish from cooling water intake systems. The concept of using fine mesh screens for exclusion of larvae relies on gentle impingement on the screen surface or retention of larvae within the screening basket, washing of screen panels or baskets to transfer organisms into a sluiceway, and then sluicing the organisms back to the source waterbody (Sharma, 1978). Fine mesh with openings as small as 0.5 millimeters (mm) has been used depending on the size of the organisms to be protected. Fine mesh screens have been used on conventional traveling screens and single-entry, double-exit screens. The ultimate success of an installation using fine mesh screens is contingent on the application of satisfactory handling and recovery facilities to allow the safe return of impinged organisms to the aquatic environment (Pagano et al, 1977).

**TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

The Big Bend Power Plant along Tampa Bay area has an intake canal with 0.5-mm mesh Ristroph screens that are used seasonally on the intakes for Units 3 and 4. At the Brunswick Power Plant in North Carolina, fine mesh is used seasonally on two of four screens has shown 84 percent reduction in entrainment compared to the conventional screen systems.

## **RESEARCH/OPERATION FINDINGS:**

- C During the mid-1980s when the screens were initially installed at Big Bend, their efficiency in reducing impingement and entrainment mortality was highly variable. The operator evaluated different approach velocities and screen rotational speeds. In addition, the operator recognized that frequent maintenance (manual cleaning) was necessary to avoid biofouling. By 1988, system performance had improved greatly. The system's efficiency in screening fish eggs (primarily drums and bay anchovy) exceeded 95 percent with 80 percent latent survival for drum and 93 percent for bay anchovy. For larvae (primarily drums, bay anchovies, blennies, and gobies), screening efficiency was 86 percent with 65 percent latent survival for drum and 66 percent for bay anchovy. Note that latent survival in control samples was also approximately 60 percent (EPRI, 1999).
- C At the Brunswick Power Plant in North Carolina, fine mesh screen has led to 84 percent reduction in entrainment compared to the conventional screen systems. Similar results were obtained during pilot testing of 1-mm screens at the Chalk Point Generating Station in Maryland. At the Kintigh Generating Station in New Jersey, pilot testing indicated 1-mm screens provided 2 to 35 times reductions in entrainment over conventional 9.5-mm screens (EPRI, 1999).
- C Tennessee Valley Authority (TVA) pilot-scale studies performed in the 1970s showed reductions in striped bass larvae entrainment up to 99 percent using a 0.5-mm screen and 75 and 70 percent for 0.97-mm and 1.3-mm screens. A full-scale test by TVA at the John Sevier Plant showed less than half as many larvae entrained with a 0.5-mm screen than 1.0 and 2.0-mm screens combined (TVA, 1976).
- C Preliminary results from a study initiated in 1987 by the Central Hudson and Gas Electric Corporation indicated that the fine mesh screens collect smaller fish compared to conventional screens; mortality for the smaller fish was relatively high, with similar survival between screens for fish in the same length category (EPRI, 1989).

## **DESIGN CONSIDERATIONS:**

Biological effectiveness for the whole cycle, from impingement to survival in the source water body, should be investigated thoroughly prior to implementation of this option. This includes:

- C The intake velocity should be very low so that if there is any impingement of larvae on the screens, it is gentle enough not to result in damage or mortality.
- C The wash spray for the screen panels or the baskets should be low-pressure so as not to result in mortality.
- C The sluiceway should provide smooth flow so that there are no areas of high turbulence; enough flow should be maintained so that the sluiceway is not dry at any time.

- 
- C The species life stage, size and body shape and the ability of the organisms to withstand impingement should be considered with time and flow velocities.
  - C The type of screen mesh material used is important. For instance, synthetic meshes may be smooth and have a low coefficient of friction, features that might help to minimize abrasion of small organisms. However, they also may be more susceptible to puncture than metallic meshes (Mussalli, 1977).

**ADVANTAGES:**

- C There are indications that fine mesh screens reduce entrainment.

**LIMITATIONS:**

- C Fine mesh screens may increase the impingement of fish, i.e., they need to be used in conjunction with properly designed and operated fish collection and return systems.
- C Due to the small screen openings, these screens will clog much faster than those with conventional 3/8-inch mesh. Frequent maintenance is required, especially in marine environments.

**REFERENCES:**

Bruggemeyer, V., D. Condrick, K. Durrel, S. Mahadevan, and D. Brizck. "Full Scale Operational Demonstration of Fine Mesh Screens at Power Plant Intakes". In Fish Protection at Steam and Hydroelectric Power Plants. EPRI CS/EA/AP-5664-SR, March 1988, pp 251-265.

Electric Power Research Institute (EPRI). Fish Protection at Cooling Water Intakes: Status Report. 1999.

EPRI. Intake Technologies: Research Status. Electrical Power Research Institute, EPRI GS-6293. March 1989.

Pagano, R., and W.H.B. Smith. Recent Developments in Techniques to Protect Aquatic Organisms at the Intakes Steam-Electric Power Plants. MITRE Corporation Technical Report 7671. November 1977.

Mussalli, Y.G., E.P. Taft, and P. Hofmann. "Engineering Implications of New Fish Screening Concepts". In Fourth Workshop on Larval Exclusion Systems For Power Plant Cooling Water Intakes, San-Diego, California, February 1978, pp 367-376.

Sharma, R.K., "A Synthesis of Views Presented at the Workshop". In Larval Exclusion Systems For Power Plant Cooling Water Intakes. San-Diego, California, February 1978, pp 235-237.

Tennessee Valley Authority (TVA). A State of the Art Report on Intake Technologies. 1976.

**DESCRIPTION:**

Wedgewire screens are designed to reduce entrainment by physical exclusion and by exploiting hydrodynamics. Physical exclusion occurs when the mesh size of the screen is smaller than the organisms susceptible to entrainment. Hydrodynamic exclusion results from maintenance of a low through-slot velocity, which, because of the screen's cylindrical configuration, is quickly dissipated, thereby allowing organisms to escape the flow field (Weisberd et al, 1984). The screens can be fine or wide mesh. The name of these screens arise from the triangular or "wedge" cross section of the wire that makes up the screen. The screen is composed of wedgewire loops welded at the apex of their triangular cross section to supporting axial rods presenting the base of the cross section to the incoming flow (Pagano et al, 1977). A cylindrical wedgewire screen is shown in the figure below. Wedgewire screens are also called profile screens or Johnson screens.

mitre report



## **Schematic of Cylindrical Wedgewire Screen (Pagano et al, 1977)**

### **TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

Wide mesh wedgewire screens are used at two large power plants, Eddystone and Campbell. Smaller facilities with wedgewire screens include Logan and Cope with fine mesh and Jeffrey with wide mesh (EPRI 1999).

### **RESEARCH/OPERATION FINDINGS:**

- C In-situ observations have shown that impingement is virtually eliminated when wedgewire screens are used (Hanson, 1977; Weisberg et al, 1984).
- C At Campbell Unit 3, impingement of gizzard shad, smelt, yellow perch, alewife, and shiner species is significantly lower than Units 1 and 2 that do not have wedgewire screens (EPRI, 1999).
- C The cooling water intakes for Eddystone Units 1 and 2 were retrofitted with wedgewire screens because over 3 million fish were reportedly impinged over a 20-month period. The wedgewire screens have generally eliminated impingement at Eddystone (EPRI, 1999).
- C Laboratory studies (Heuer and Tomljanovitch, 1978) and prototype field studies (Lifton, 1979; Delmarva Power and Light, 1982; Weisberg et al, 1983) have shown that fine mesh wedgewire screens reduce entrainment.
- C One study (Hanson, 1977) found that entrainment of fish eggs (striped bass), ranging in diameter from 1.8 mm to 3.2 mm, could be eliminated with a cylindrical wedgewire screen incorporating 0.5 mm slot openings. However, striped bass larvae, measuring 5.2 mm to 9.2 mm were generally entrained through a 1 mm slot at a level exceeding 75 percent within one minute of release in the test flume.
- C At the Logan Generating Station in New Jersey, monitoring shows shows 90 percent less entrainment of larvae and eggs through the 1 mm wedgewire screen than conventional screens. In situ testing of 1 and 2-mm wedgewire screens was performed in the St. John River for the Seminole Generating Station Units 1 and 2 in Florida in the late 1970s. This testing showed virtually no impingement and 99 and 62 percent reductions in larvae entrainment for the 1-mm and 2-mm screens, respectively, over conventional screen (9.5 mm) systems (EPRI, 1999).

### **DESIGN CONSIDERATIONS:**

- C To minimize clogging, the screen should be located in an ambient current of at least 1 feet per second (ft/sec).
- C A uniform velocity distribution along the screen face is required to minimize the entrapment of motile organisms and to minimize the need of debris backflushing.
- C In northern latitudes, provisions for the prevention of frazil ice formation on the screens must be considered.
- C Allowance should be provided below the screens for silt accumulation to avoid blockage of the water flow (Mussalli et al, 1980).

#### **ADVANTAGES:**

- C Wedgewire screens have been demonstrated to reduce impingement and entrainment in laboratory and prototype field studies.

#### **LIMITATIONS:**

- C The physical size of the screening device is limiting in most passive systems, thus, requiring the clustering of a number of screening units. Siltation, biofouling and frazil ice also limit areas where passive screens such as wedgewire can be utilized.
- C Because of these limitations, wedgewire screens may be more suitable for closed-cycle make-up intakes than once-through systems. Closed-cycle systems require less flow and fewer screens than once-through intakes; back-up conventional screens can therefore be used during maintenance work on the wedge-wire screens (Mussalli et al, 1980).

#### **REFERENCES:**

Delmarva Ecological Laboratory. Ecological Studies of the Nanticoke River and Nearby Area. Vol II. Profile Wire Studies. Report to Delmarva Power and Light Company. 1980.

EEI Power Statistics Database. Prepared by the Utility Data Institute for the Edison Electric Institute. Washington, D.C., 1993.

Electric Power Research Institute (EPRI). Fish Protection at Cooling Water Intakes: Status Report. 1999.

Hanson, B.N., W.H. Bason, B.E. Beitz and K.E. Charles. "A Practical Intake Screen which Substantially Reduces the Entrainment and Impingement of Early Life stages of Fish". In Fourth National Workshop on Entrainment and Impingement, L.D. Jensen (Editor). Ecological Analysts, Inc., Melville, NY. Chicago, December 1977, pp 393-407.

Heuer, J.H. and D.A. Tomljanovitch. "A Study on the Protection of Fish Larvae at Water Intakes

Using Wedge-Wire Screening". In Larval Exclusion Systems For Power Plant Cooling Water Intakes. R.K. Sharmer and J.B. Palmer, eds, Argonne National Lab., Argonne, IL. February 1978, pp 169-194.

Lifton, W.S. "Biological Aspects of Screen Testing on the St. Johns River, Palatka, Florida". In Passive Screen Intake Workshop, Johnson Division UOP Inc., St. Paul, MN. 1979.

Mussalli, Y.G., E.P. Taft III, and J. Larsen. "Offshore Water Intakes Designated to Protect Fish". Journal of the Hydraulics Division, Proceedings of the America Society of Civil Engineers. Vol. 106, No HY11, November 1980, pp 1885-1901.

Pagano R. and W.H.B. Smith. Recent Developments in Techniques to Protect Aquatic Organisms at the Intakes Steam-Electric Power Plants. MITRE Corporation Technical Report 7671. November 1977.

Weisberg, S.B., F. Jacobs, W.H. Burton, and R.N. Ross. Report on Preliminary Studies Using the Wedge Wire Screen Model Intake Facility. Prepared for State of Maryland, Power Plant Siting Program. Prepared by Martin Marietta Environmental Center, Baltimore, MD. 1983.

Weisberg, S.B., W.H. Burton, E.A., Ross, and F. Jacobs. The effects of Screen Slot Size, Screen Diameter, and Through-Slot Velocity on Entrainment of Estuarine Ichthyoplankton Through Wedge-Wire Screens. Martin Marietta Environmental Studies, Columbia MD. August 1984.

**DESCRIPTION:**

Perforated pipes draw water through perforations or slots in a cylindrical section placed in the waterway. The term “perforated” is applied to round perforations and elongated slots as shown in the figure below. The early technology was not efficient: velocity distribution was poor, it served specifically to screen out detritus, and was not used for fish protection (ASCE, 1982). Inner sleeves have been added to perforated pipes to equalize the velocities entering the outer perforations. Water entering a single perforated pipe intake without an internal sleeve will have a wide range of entrance velocities and the highest will be concentrated at the supply pipe end. These systems have been used at locations requiring small amounts of water such as make-up water. However, experience at steam electric plants is very limited (Sharma, 1978).

(Figure ASCE page 79).

**Perforations and Slots in Perforated Pipe (ASCE, 1982)****TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

Nine steam electric units in the U.S. use perforated pipes. Each of these units uses closed-cycle cooling systems with relatively low make-up intake flow ranging from 7 to 36 MGD (EEI, 1993).

**RESEARCH/OPERATION FINDINGS:**

- C Maintenance of perforated pipe systems requires control of biofouling and removal of debris from clogged screens.

- C For withdrawal of relatively small quantities of water, up to 50,000 gpm, the perforated pipe inlet with an internal perforated sleeve offers substantial protection for fish. This particular design serves the Washington Public Power Supply System on the Columbia River (Richards, 1977).
- C No information is available on the fate of the organisms impinged at the face of such screens.

#### **DESIGN CONSIDERATIONS:**

The design of these systems is fairly well established for various water intakes (ASCE, 1982).

#### **ADVANTAGES:**

The primary advantage is the absence of a confined channel in which fish might become trapped.

#### **LIMITATIONS:**

Clogging, frazil ice formation, biofouling and removal of debris limit this technology to small flow withdrawals.

#### **REFERENCES:**

American Society of Civil Engineers. Task Committee on Fish-handling of Intake Structures of the Committee of Hydraulic Structures. Design of Water Intake Structures for Fish Protection. ASCE, New York, N.Y. 1982.

EEI Power Statistics Database. Prepared by the Utility Data Institute for the Edison Electric Institute. Washington, D.C., 1993.

Richards, R.T. 1977. "Present Engineering Limitations to the Protection of Fish at Water Intakes". In Fourth National Workshop on Entrainment and Impingement, L.D. Jensen Editor, Chicago, December 1977, pp 415-424.

Sharma, R.K. "A Synthesis of Views Presented at the Workshop". In Larval Exclusion Systems For Power Plant Cooling Water Intakes. San-Diego, California, February 1978, pp 235-237.

**DESCRIPTION:**

Porous dikes, also known as leaky dams or leaky dikes, are filters resembling a breakwater surrounding a cooling water intake. The core of the dike consists of cobble or gravel, which permits free passage of water. The dike acts both as a physical and a behavioral barrier to aquatic organisms and is depicted in the figure below. The filtering mechanism includes a breakwater or some other type of barrier and the filtering core (Fritz, 1980). Tests conducted to date have indicated that the technology is effective in excluding juvenile and adult fish. However, its effectiveness in screening fish eggs and larvae is not established (ASCE, 1982).

**Porous Dike** (Schrader and Ketschke, 1978)

**TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

- C Two facilities which are both testing facilities and have used the technology are: the Point Beach Nuclear Plant in Wisconsin and the Baily Generating Station in Indiana (EPRI, 1985). The Brayton Point Generating Station in Massachusetts has

also tested the technology.

#### **RESEARCH/OPERATION FINDINGS:**

- C** Schrader and Ketschke (1978) studied a porous dike system at the Lakeside Plant on Lake Michigan and found that numerous fish penetrated large void spaces, but for most fish accessibility was limited.
- C** The biological effectiveness of screening of fish larvae and the engineering practicability have not been established (ASCE, 1982).
- C** The size of the pores in the dike dictates the degree of maintenance due to biofouling and clogging by debris.
- C** Ice build-up and frazil ice may create problems as evidenced at the Point Beach Nuclear Plant (EPRI, 1985).

#### **DESIGN CONSIDERATIONS:**

- C** The presence of currents past the dike is an important factor which may probably increase biological effectiveness.
- C** The size of pores in the dike determines the extent of biofouling and clogging by debris (Sharma, 1978).
- C** Filtering material must be of a size that permits free passage of water but still prevents entrainment and impingement.

#### **ADVANTAGES:**

- C** Dikes can be used at marine, fresh water, and estuarine locations.

#### **LIMITATIONS:**

- C** The major problem with porous dikes comes from clogging by debris and silt, and from fouling by colonization of fish and plant life.
- C** Backflushing, which is often used by other systems for debris removal, is not feasible at a dike installation.
- C** Predation of organisms screened at these dikes may offset any biological effectiveness (Sharma, 1978).



## **REFERENCES:**

American Society of Civil Engineers. Task Committee on Fish-handling of Intake Structures of the Committee of Hydraulic Structures. Design of Water Intake Structures for Fish Protection. ASCE, New York, N.Y. 1982.

EPRI. Intake Research Facilities Manual. Prepared by Lawler, Matusky & Skelly Engineers, Pearl River, New York for Electric Power Research Institute. EPRI CS-3976. May 1985.

Fritz, E.S. Cooling Water Intake Screening Devices Used to Reduce Entrainment and Impingement. Fish and Wildlife Service, Topical Briefs: Fish and Wildlife Resources and Electric Power Generation, No 9. July 1980.

Schrader, B.P. and B.A. Ketschke. "Biological Aspects of Porous-Dike Intake Structures". In Larval Exclusion Systems For Power Plant Cooling Water Intakes, San-Diego, California, August 1978, pp 51-63.

Sharma, R.K. "A Synthesis of Views Presented at the Workshop". In Larval Exclusion Systems For Power Plant Cooling Water Intakes. San-Diego, California, February 1978, pp 235-237.

**DESCRIPTION:**

Louver systems are comprised of a series of vertical panels placed at an angle to the direction of the flow (typically 15 to 20 degrees). Each panel is placed at an angle of 90 degrees to the direction of the flow (Hadderingh, 1979). The louver panels provide an abrupt change in both the flow direction and velocity (see figure below). This creates a barrier, which fish can immediately sense and will avoid. Once the change in flow/velocity is sensed by fish, they typically align with the direction of the current and move away laterally from the turbulence. This behavior further guides fish into a current created by the system, which is parallel to the face of the louvers. This current pulls the fish along the line of the louvers until they enter a fish bypass or other fish handling device at the end of the louver line. The louvers may be either fixed or rotated similar to a traveling screen. Flow straighteners are frequently placed behind the louver systems.

These types of barriers have been very successful and have been installed at numerous irrigation intakes, water diversion projects, and steam electric and hydroelectric facilities. It appears that this technology has, in general, become accepted as a viable option to divert juvenile and adult fish.

**Top view of a Louver Barrier with Fish By-Pass (Hadderingh, 1979)****TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

Louver barrier devices have been tested and/or are in use at the following facilities: the California Department of Water Resource's Tracy Pumping Plant; the California Department of Fish and Game's Delta Fish Protective Facility in Bryon; the Conte Anadromous Fish Research Center in Massachusetts, and the San Onofre Nuclear Generating Station in

California (EPA, 1976; EPRI, 1985; EPRI, 1999). In addition, three other plants also have louvers at their facilities: the Ruth Falls Power Plant in Nova Scotia, the Nine Mile Point Nuclear Power Station on Lake Erie, and T.W. Sullivan Hydroelectric Plant in Oregon. Louvers have also been tested at the Ontario Hydro Laboratories in Ontario, Canada (Ray et al, 1976).

#### **RESEARCH/OPERATION FINDINGS:**

Research has shown the following generalizations to be true regarding louver barriers:

1) the fish separation performance of the louver barrier decreases with an increase in the velocity of the flow through the barrier; 2) efficiency increases with fish size (EPA, 1976; Hadderingh, 1979); 3) individual louver misalignment has a beneficial effect on the efficiency of the barrier; 4) the use of center walls provides the fish with a guide wall to swim along thereby improving efficiency (EPA, 1976); and 5) the most effective slat spacing and array angle to flow depends upon the size, species and ability of the fish to be diverted (Ray et al, 1976).

In addition, the following conclusions were drawn during specific studies:

- Testing of louvered intake structures offshore was performed at a New York facility. The louvers were spaced 10 inches apart to minimize clogging. The array was angled at 11.5 percent to the flow. Center walls were provided for fish guidance to the bypass. Test species included alewife and rainbow smelt. The mean efficiency predicted was between 22 and 48 percent (Mussalli 1980).
- During testing at the Delta Facility's intake in Byron California, the design flow was 6,000 cubic feet per second (cfs), the approach velocity was 1.5 to 3.5 feet per second (ft/sec), and the bypass velocities were 1.2 to 1.6 times the approach velocity. Efficiencies were found to drop with an increase in velocity through the louvers. For example, at 1.5 to 2 ft/sec the efficiency was 61 percent for 15 millimeter long fish and 95 percent for 40 millimeter fish. At 3.5 ft/sec, the efficiencies were 35 and 70 percent (Ray et al. 1976).
- The efficiency of a louver device is highly dependent upon the length and swimming performance of a fish. Efficiencies of lower than 80 percent have been seen at facilities where fish were less than 1 to 1.6 inches in length (Mussalli, 1980).
- In the 1990s, an experimental louver bypass system was tested at the USGS' Conte Anadromous Fish Research Center in Massachusetts. This testing showed guidance efficiencies for Connecticut River species of 97 percent for a "wide array" of louvers and 100 percent for a "narrow array" (EPRI, 1999).
- At the Tracy Fish Collection Facility located along the San Joaquin River in California, testing was performed from 1993 and 1995 to determine the guidance efficiency of a system with primary and secondary louvers. The results for green

and white sturgeon, American shad, splittail, white catfish, delta smelt, Chinook salmon, and striped bass showed mean diversion efficiencies ranging from 63 (splittail) to 89 percent (white catfish) (EPRI, 1999).

- In 1984 at the San Onofre Station, a total of 196,978 fish entered the louver system with 188,583 returned to the waterbody and 8,395 impinged. In 1985, 407,755 entered the louver system with 306,200 returned and 101,555 impinged. Therefore, the guidance efficiencies in 1984 and 1985 were 96 and 75 percent, respectively. However, 96-hour survival rates for some species, i.e., anchovies and croakers, were 50 percent or less. Louvers were originally considered for use at San Onofre because of 1970s pilot testing at the Redondo Beach Station in California where maximum guidance efficiencies of 96-100 percent were observed. (EPRI, 1999)
- At the Maxwell Irrigation Canal in Oregon, louver spacing was 5.0 cm with a 98 percent efficiency of deflecting immature steelhead and above 90 percent efficiency for the same species with a louver spacing of 10.8 cm.
- At the Ruth Falls Power Plant in Nova Scotia, the results of a five-year evaluation for guiding salmon smelts showed that the optimum spacing was to have wide bar spacing at the widest part of the louver with a gradual reduction in the spacing approaching the bypass. The site used a bypass:approach velocity ratio of 1.0 : 1.5 (Ray et al, 1976).
- Coastal species in California were deflected optimally (Schuler and Larson, 1974 in Ray et al, 1976) with 2.5 cm spacing of the louvers, 20 degree louver array to the direction of flow and approach velocities of 0.6 cm per second.
- At the T.W. Sullivan Hydroelectric Plant along the Willamette River in Oregon, the louver system is estimated to be 92 percent effective in diverting spring Chinook, 82 percent for all Chinook, and 85 percent for steelhead. The system has been optimized to reduce fish injuries such that the average injury occurrence is only 0.44 percent (EPRI, 1999).

#### **DESIGN CONSIDERATIONS:**

The most important parameters of the design of louver barriers include the following:

- The angle of the louver vanes in relation to the channel velocity ,
- The spacing between the louvers which is related to the size of the fish,
- Ratio of bypass velocity to channel velocity,

- Shape of guide walls,
- Louver array angles, and
- Approach velocities.

Site-specific modeling may be needed to take into account species-specific considerations and optimize the design efficiency (EPA, 1976; O’Keefe, 1978).

#### **ADVANTAGES:**

- Louver designs have been shown to be very effective in diverting fish (EPA, 1976).

#### **LIMITATIONS:**

- The costs of installing intakes with louvers may be substantially higher than other technologies due to design costs and the precision required during construction.
- Extensive species-specific field testing may be required.
- The shallow angles required for the efficient design of a louver system require a long line of louvers increasing the cost as compared to other systems (Ray et al, 1976).
- Water level changes must be kept to a minimum to maintain the most efficient flow velocity.
- Fish handling devices are needed to take fish away from the louver barrier.
- Louver barriers may, or may not, require additional screening devices for removing solids from the intake waters. If such devices are required, they may add a substantial cost to the system (EPA, 1976).
- Louvers may not be appropriate for offshore intakes (Mussalli, 1980).

#### **REFERENCES:**

Chow, W., I.P. Murarka, R.W. Broksen. “Entrainment and Impingement in Power Plant Cooling Systems.” Literature Review. Journal Water Pollution Control Federation. 53 (6)(1981):965-973.

U.S. EPA. Development Document for Best Technology Available for the Location, Design, Construction, and Capacity of Cooling Water Intake Structures for Minimizing Adverse Environmental Impact. U.S. Environmental Protection Agency, Effluent Guidelines Division, Office of Water and Hazardous Materials. April 1976.

Electric Power Research Institute (EPRI). Fish Protection at Cooling Water Intakes: Status Report. 1999.

EPRI. Intake Research Facilities Manual. Prepared by Lawler, Matusky & Skelly Engineers, Pearl River, New York for Electric Power Research Institute. EPRI CS-3976. May 1985.

Hadderingh, R.H. "Fish Intake Mortality at Power Stations, the Problem and its Remedy." N.V. Kema, Arnheem, Netherlands. Hydrological Bulletin 13(2-3) (1979): 83-93.

Mussalli, Y.G., E.P. Taft, and P. Hoffman. "Engineering Implications of New Fish Screening Concepts," In Fourth National Workshop on Entrainment and impingement, L.D. Jensen (Ed.), Ecological Analysts, Inc. Melville, NY. Chicago, Dec. 1977.

Mussalli, Y.G., E.P Taft III and J. Larson. "Offshore Water Intakes Designed to Protect Fish." Journal of the Hydraulics Division Proceedings of the American Society of Civil Engineers. Vol. 106 Hy11 (1980): 1885-1901.

O'Keefe, W., Intake Technology Moves Ahead. Power. January 1978.

Ray, S.S. and R.L. Snipes and D.A. Tomljanovich. A State-of-the-Art Report on Intake Technologies. Prepared for Office of Energy, Minerals, and Industry, Office of Research and Development. U.S. Environmental Protection Agency, Washington, D.C. by the Tennessee Valley Authority. EPA 600/7-76-020. October 1976.

Uziel, Mary S. "Entrainment and Impingement at Cooling Water Intakes." Literature Review. Journal Water Pollution Control Federation. 52 (6) (1980): 1616-1630.

#### **ADDITIONAL REFERENCES:**

Adams, S.M. et al. Analysis of the Prairie Island Nuclear Generating Station- Intake Related Studies. Report to Minnesota Pollution Control Agency. Oak Ridge National Lab. Oak Ridge TN (1979).

Bates, D.W. and R. Vinsonhaler, "The Use of Louvers for Guiding Fish." Trans. Am. Fish. Soc. 86 (1956):39-57.

Bates, D.W., and S.G., Jewett Jr., "Louver Efficiency in Deflecting Downstream Migrant Steelhead, " Trans. Am. Fish Soc. 90(3)(1961):336-337.

Cada, G.G., and A.T. Szluha. "A Biological Evaluation of Devices Used for Reducing Entrainment and Impingement Losses at Thermal Power Plants." In International Symposium on the Environmental Effects of Hydraulic Engineering Works. Environmental Sciences Division, Publication No. 1276. Oak Ridge Nat'l. Lab., Oak Ridge TN (1978).

Cannon, J.B., et al. "Fish Protection at Steam Electric Power Plants: Alternative Screening Devices." ORAL/TM-6473. Oak Ridge Nat'l. Lab. Oak Ridge, TN (1979).

Downs, D.I., and K.R. Meddock, "Design of Fish Conserving Intake System," Journal of the Power Division, ASCE, Vol. 100, No. P02, Proc. Paper 1108 (1974): 191-205.

Ducharme, L.J.A. "An Application of Louver Deflectors for Guiding Atlantic Salmon (*Salmo salar*) Smolts from Power Turbines." Journal Fisheries Research Board of Canada 29 (1974):1397-1404.

Hallock, R.J., R.A. Iselin, and D.H.J. Fry, Efficiency Tests of the Primary Louver Systems, Tracy Fish Screen, 1966-67. Marine Resources Branch, California Department of Fish and Game (1968).

Katapodis, C. et al. A Study of Model and Prototype Culvert Baffling for Fish Passage. Fisheries and Marine Service, Tech. Report No. 828. Winnipeg, Manitoba (1978).

Kerr, J.E., "Studies on Fish Preservation at the Contra Costa Steam Plant of the Pacific Gas and Electric Co," California Fish and Game Bulletin No. 92 (1953).

Marcy, B.C., and M.D. Dahlberg. Review of Best Technology Available for Cooling Water Intakes. NUS Corporation. Pittsburgh, PA (1978).

NUS Corp., "Review of Best Technology Available for Cooling Water Intakes." Los Angeles Dept. of Water & Power Report, Los Angeles CA (1978).

Schuler, V.J., "Experimental Studies In Guiding Marine Fishes of Southern California with Screens and Louvers," Ichthyol. Assoc., Bulletin 8 (1973).

Skinner, J.E. "A Functional Evaluation of Large Louver Screen Installation and Fish Facilities Research on California Water Diversion Projects." In: L.D. Jensen, ed. Entrainment and Intake Screening. Proceedings of the Second Entrainment and Intake Screening Workshop. The John Hopkins University, Baltimore, Maryland. February 5-9, 1973. pp 225-249 (Edison Electric Institute and Electric Power Research Institute, EPRI Publication No. 74-049-00-5 (1974).

Stone and Webster Engineering Corporation, Studies to Alleviate Potential Fish Entrapment Problems - Final Report, Nine Mile Point Nuclear Station - Unit 2. Prepared for Niagara Mohawk Power Corporation, Syracuse, New York, May 1972.

Stone and Webster Engineering Corporation. Final Report, Indian Point Flume Study. Prepared for Consolidated Edison Company of New York, IN. July 1976.

Taft, E.P., and Y.G. Mussalli, "Angled Screens and Louvers for Diverting Fish at Power Plants," Proceedings of the American Society of Civil Engineers, Journal of Hydraulics Division. Vol 104 (1978):623-634.

Thompson, J.S., and Paulick, G.J. An Evaluation of Louvers and Bypass Facilities for Guiding Seaward Migrant Salmonid Past Mayfield Dam in West Washington. Washington Department of

Fisheries, Olympia, Washington (1967).

Watts, F.J., "Design of Culvert Fishways." University of Idaho Water Resources Research Institute Report, Moscow, Idaho (1974).

**Fish Diversion or Avoidance Systems**

**Fact Sheet No. 9: Velocity Cap**

**DESCRIPTION:**

A velocity cap is a device that is placed over vertical inlets at offshore intakes (see figure below). This cover converts vertical flow into horizontal flow at the entrance into the intake. The device works on the premise that fish will avoid rapid changes in horizontal flow. Fish do not exhibit this same avoidance behavior to the vertical flow that occurs without the use of such a device. Velocity caps have been implemented at many offshore intakes and have been successful in decreasing the impingement of fish.

**Typical Offshore Cooling Water Intake Structure with Velocity Caps (Helrey, 1985; ASCE, 1982)**

**TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

The available literature (EPA, 1976; Hanson, 1979; and Pagano et al, 1977) states that velocity caps have been installed at offshore intakes in Southern California, the Great Lakes Region, the Pacific Coast, the Caribbean and overseas; however, exact locations are not specified.

Velocity caps are known to have been installed at the El Segundo, Redondo Beach, and Huntington Beach Steam Electric Stations and the San Onofre Nuclear Generation Station in Southern California (Mussalli, 1980; Pagano et al, 1977; EPRI, 1985).



Model tests have been conducted by a New York State Utility (ASCE, 1982) and several facilities have installed velocity caps in the New York State /Great Lakes Area including the Nine Mile Point Nuclear Station, the Oswego Steam Electric Station, and the Kintigh Generating Station (EPRI, 1985).

Additional known facilities with velocity caps include the Edgewater Generation Station in Wisconsin, the Seabrook Power Plant in New Hampshire, and the Nanticoke Thermal Generating Station in Ontario, Canada (EPRI, 1985).

#### **RESEARCH/OPERATION FINDINGS:**

- Horizontal velocities within a range of 0.5 to 1.5 feet per second (ft/sec) did not significantly affect the efficiency of a velocity cap tested at a New York facility; however, this design velocity may be specific to the species present at that site (ASCE, 1982).
- Preliminary decreases in fish entrapment averaging 80 to 90 percent were seen at the El Segundo and Huntington Beach Steam Electric Plants (Mussalli, 1980).
- Performance of the velocity cap may be associated with cap design and the total volumes of water flowing into the cap rather than to the critical velocity threshold of the cap (Mussalli, 1980).

#### **DESIGN CONSIDERATIONS:**

- Designs with rims around the cap edge prevent water from sweeping around the edge causing turbulence and high velocities, thereby providing more uniform horizontal flows (EPA, 1976; Mussalli, 1980).
- Site-specific testing should be conducted to determine appropriate velocities to minimize entrainment of particular species in the intake (ASCE, 1982).
- Most structures are sized to achieve a low intake velocity between 0.5 and 1.5 ft/sec to lessen the chances of entrainment (ASCE, 1982).
- Design criteria developed for a model test conducted by Southern California Edison Company used a velocity through the cap of 0.5 to 1.5 ft/sec; the ratio of the dimension of the rim to the height of the intake areas was 1.5 to 1 (ASCE, 1982; Schuler, 1975).

#### **ADVANTAGES:**

- Efficiencies of velocity caps on West Coast offshore intakes have exceeded 90 percent (ASCE, 1982).

#### **LIMITATIONS:**

- Velocity caps are difficult to inspect due to their location under water (EPA, 1976).
- In some studies, the velocity cap only minimized the entrainment of fish and did not eliminate it. Therefore, additional fish recovery devices are needed when using such systems (ASCE, 1982; Mussalli, 1980).
- Velocity caps are ineffective in preventing passage of non-motile organisms and early life stage fish (Mussalli, 1980).

#### **REFERENCES:**

ASCE. Design of Water Intake Structures for Fish Protection. American Society of Civil Engineers, New York, NY. 1982.

EPRI. Intake Research Facilities Manual. Prepared by Lawler, Matusky & Skelly Engineers, Pearl River, New York for Electric Power Research Institute. EPRI CS-3976. May 1985.

Hanson, C.H., et al. "Entrapment and Impingement of Fishes by Power Plant Cooling Water Intakes: An Overview." Marine Fisheries Review. October 1977.

Mussalli, Y.G., E.P Taft III and J. Larson. "Offshore Water Intakes Designed to Protect Fish." Journal of the Hydraulics Division Proceedings of the American Society of Civil Engineers, Vol. 106 Hy11 (1980): 1885-1901.

Pagano R. and W.H.B. Smith. Recent Development in Techniques to Protect Aquatic Organisms at the Water Intakes of Steam Electric Power Plants. Prepared for Electricite' de France. MITRE Technical Report 7671. November 1977.

Ray, S.S. and R.L. Snipes and D.A. Tomljanovich. A State-of-the-Art Report on Intake Technologies. Prepared for Office of Energy, Minerals, and Industry, Office of Research and Development. U.S. Environmental Protection Agency, Washington, D.C. by the Tennessee Valley Authority. EPA 600/7-76-020. October 1976.

U.S. EPA. Development Document for Best Technology Available for the Location, Design, Construction, and Capacity of Cooling Water Intake Structures for Minimizing Adverse Environmental Impact. U.S. Environmental Protection Agency, Effluent Guidelines Division, Office of Water and Hazardous Materials. April 1976.

#### **ADDITIONAL REFERENCES:**

Maxwell, W.A. Fish Diversion for Electrical Generating Station Cooling Systems a State of the Art Report. Southern Nuclear Engineering, Inc. Report SNE-123, NUS Corporation, Dunedin, FL. (1973) 78p.

Weight, R.H. "Ocean Cooling Water System for 800 MW Power Station." J. Power Div., Proc. Am.

Soc. Civil Engr. 84(6)(1958):1888-1 to 1888-222.

Stone and Webster Engineering Corporation. Studies to Alleviate Fish Entrapment at Power Plant Cooling Water Intakes, Final Report. Prepared for Niagara Mohawk Power Corporation and Rochester Gas and Electric Corporation, November 1976.

Richards, R.T. "Power Plant Circulating Water Systems - A Case Study." Short Course on the Hydraulics of Cooling Water Systems for Thermal Power Plants. Colorado State University. June 1978.

<b>Fish Diversion or Avoidance Systems</b>	<b>Fact Sheet No. 10: Fish Barrier Nets</b>
<b>DESCRIPTION:</b> <p>Fish barrier nets are wide mesh nets, which are placed in front of the entrance to an intake structure (see figure below). The size of the mesh needed is a function of the species that are present at a particular site. Fish barrier nets have been used at numerous facilities and lend themselves to intakes where the seasonal migration of fish and other organisms require fish diversion facilities for only specific times of the year.</p> <p style="text-align: center;"><b>V-Arrangement of Fish Barrier Net (ASCE, 1982)</b></p> <b>TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:</b> <p>The Bowline Point Generating Station, the J.P. Pulliam Power Plant in Wisconsin, the Ludington Storage Plant in Michigan, and the Nanticoke Thermal Generating Station in Ontario use barrier nets (EPRI, 1999).</p> <p>Barrier Nets have been tested at the Detroit Edison Monroe Plant on Lake Erie and the Chalk Point Station on the Patuxent River in Maryland (ASCE, 1982; EPRI, 1985). The Chalk Point Station now uses barrier nets seasonally to reduce fish and Blue Crab entry into the intake canal (EPRI, 1985). The Pickering Generation Station in Ontario evaluated rope nets in 1981 illuminated by strobe lights (EPRI, 1985).</p> <b>RESEARCH/OPERATION FINDINGS:</b>	

- At the Bowline Point Generating Station in New York, good results (91 percent impingement reductions) have been realized with a net placed in a V arrangement around the intake structure (ASCE, 1982; EPRI, 1999).
- In 1980, a barrier net was installed at the J.R. Whiting Plant (Michigan) to protect Maumee Bay. Prior to net installation, 17,378,518 fish were impinged on conventional traveling screens. With the net, sampling in 1983 and 84 showed 421,978 fish impinged (97 percent effective), sampling in 1987 showed 82,872 fish impinged (99 percent effective), and sampling in 1991 showed 316,575 fish impinged (98 percent effective) (EPRI, 1999).

- Nets tested with high intake velocities (greater than 1.3 feet per second) at the Monroe Plant have clogged and subsequently collapsed. This has not occurred at facilities where the velocities are 0.4 to 0.5 feet per second (ASCE, 1982).
- Barrier nets at the Nanticoke Thermal Generating Station in Ontario reduced intake of fish by 50 percent (EPRI, 1985).
- The J.P. Pulliam Generating Station in Wisconsin uses dual barrier nets (0.64 centimeters stretch mesh) to permit net rotation for cleaning. Nets are used from April to December or when water temperatures go above 4 degrees Celsius. Impingement has been reduced by as much as 90 percent. Operating costs run about \$5,000 per year, and nets are replaced every two years at \$2,500 per net (EPRI, 1985).
- The Chalk Point Station in Maryland realized operational costs of \$5,000-10,000 per year with the nets being replaced every two years (EPRI, 1985). However, crab impingement has been reduced by 84 percent and overall impingement liability has been reduced from \$2 million to \$140,000 (EPRI, 1999).
- The Ludington Storage Plant (Michigan) provides water from Lake Michigan to a number of power plant facilities. The plant has a 2.5-mile long barrier net that has successfully reduced impingement and entrainment. The overall net effectiveness for target species (five salmonids, yellow perch, rainbow smelt, alewife, and chub) has been over 80 percent since 1991 and 96 percent since 1995. The net is deployed from mid-April to mid-October, with storms and icing preventing use during the remainder of the year (EPRI, 1999).

#### **DESIGN CONSIDERATIONS:**

- The most important factors to consider in the design of a net barrier are the site-specific velocities and the potential for clogging with debris (ASCE, 1982).
- The size of the mesh must permit effective operations, without excessive clogging. Designs at the Bowline Point Station in New York have 0.15 and 0.2 inch openings in the mesh nets, while the J.P. Pulliam Plant in Wisconsin has 0.25 inch openings (ASCE, 1982).

**ADVANTAGES:**

- Net barriers, if operating properly, should require very little maintenance.
- Net barriers have relatively little cost associated with them.

**LIMITATIONS:**

- Net barriers are not effective for the protection of the early life stages of fish or zooplankton (ASCE, 1982).

**REFERENCES:**

ASCE. Design of Water Intake Structures for Fish Protection. American Society of Civil Engineers (1982).

Electric Power Research Institute (EPRI). Fish Protection at Cooling Water Intakes: Status Report. 1999.

EPRI. Intake Research Facilities Manual. Prepared by Lawler, Matusky & Skelly Engineers, Pearl River, New York for Electric Power Research Institute. EPRI CS-3976. May 1985.

Lawler, Matusky, and Skelly Engineers. 1977 Hudson River Aquatic Ecology Studies at the Bowline Point Generating Stations. Prepared for Orange and Rockland Utilities, Inc. Pearl River, NY. 1978.

**DESCRIPTION:**

Aquatic filter barrier systems are barriers that employ a filter fabric designed to allow for passage of water into a cooling water intake structure, but exclude aquatic organisms. These systems are designed to be placed some distance from the cooling water intake structure within the source waterbody and act as a filter for the water that enters into the cooling water system. These systems may be floating, flexible, or fixed. Since these systems generally have such a large surface area, the velocities that are maintained at the face of the permeable curtain are very low. One company, Gunderboom, Inc., has a patented full-water-depth filter curtain comprised of polyethylene or polypropylene fabric that is suspended by flotation billets at the surface of the water and anchored to the substrate below. The curtain fabric is manufactured as a matting of minute unwoven fibers with an apparent opening size of 20 microns. The Gunderboom Marine/Aquatic Life Exclusion System (MLES)<sup>™</sup> also employs an automated “air burst”<sup>™</sup> technology to periodically shake the material and pass air bubbles through the curtain system to clean it of sediment buildup and release any other material back in to the water column.

**Gunderboom Marine/Aquatic Life Exclusion System (Gunderboom, Inc., 1999)****TESTING FACILITIES AND/OR FACILITIES USING THE TECHNOLOGY:**

- C Gunderboom MLES<sup>™</sup> have been tested and are currently installed on a seasonal basis at Unit 3 of the Lovett Station in New York. Prototype testing of the Gunderboom system began in 1994 as a means of lowering ichthyoplankton entrainment at Unit 3. This was the first use of the technology at a cooling water

intake structure. The Gunderboom tested was a single layer fabric. Material clogging resulted in loss of filtration capacity and boom submergence within 12 hours of deployment. Ichthyoplankton monitoring while the boom was intact indicated an 80 percent reduction in entrainable organisms (Lawler, Matusky, and Skelly Engineers, 1996).

- C A Gunderboom MLES™ was effectively deployed at the Lovett Station for 43 days in June and July of 1998 using an Air-Burst cleaning system and newly designed deadweight anchoring system. The cleaning system coupled with a perforated material proved effective at limiting sediment on the boom, however it required an intensive operational schedule (Lawler, Matusky, and Skelly Engineers, 1998).
- C A 1999 study was performed on the Gunderboom MLES™ at the Lovett Station in New York to qualitatively determine the characteristics of the fabric with respect to the impingement of ichthyoplankton at various flow regimes. Conclusions were that the viability of striped bass eggs and larvae were not affected (Lawler, Matusky, and Skelly Engineers, 1999).
- C Ichthyoplankton sampling at Unit 3 (with Gunderboom MLES™ deployed) and Unit 4 (without Gunderboom) in May through August 2000 showed an overall effectiveness of approximately 80 percent. For juvenile fish, the density at Unit 3 was 58 percent lower. For post yolk-sac larvae, densities were 76 percent lower. For yolk-sac larvae, densities were 87 percent lower (Lawler, Matusky & Skelly Engineers 2000).

#### **RESEARCH/OPERATION FINDINGS:**

Extensive testing of the Gunderboom MLES™ has been performed at the Lovett Station in New York. Anchoring, material, cleaning, and monitoring systems have all been redesigned to meet the site-specific conditions in the waterbody and to optimize the operations of the Gunderboom. Although this technology has been implemented at only one cooling water intake structure, it appears to be a promising technology to reduce impingement and entrainment impacts. It is also being evaluated for use at the Contre Costa Power Plant in California.

#### **DESIGN CONSIDERATIONS:**

The most important parameters in the design of a Gunderboom® Marine/Aquatic Life Exclusion System include the following (Gunderboom, Inc. 1999):

- Size of booms designed for 3-5 gpm per square foot of submerged fabric. Flows greater than 10-12 gallons per minute.
- Flow-through velocity is approximately 0.02 ft/s.
- Performance monitoring and regular maintenance.

**ADVANTAGES:**

- Can be used in all waterbody types.
- All larger and nearly all other organisms can swim away from the barrier because of low velocities.
- Little damage is caused to fish eggs and larvae if they are drawn up against the fabric.
- Modulized panels may easily be replaced.
- Easily deployed for seasonal use.
- Biofouling not significant.
- Impinged organisms released back into the waterbody.
- Benefits relative to cost appear to be very promising, but remain unproven to date.
- Installation can occur with no or minimal plant shutdown.

**LIMITATIONS:**

- Currently only a proven technology for this application at one facility.
- Extensive waterbody-specific field testing may be required.
- May not be appropriate for conditions with large fluctuations in ambient flow and heavy currents and wave action.
- High level of maintenance and monitoring required.
- Higher flow facilities may require very large surface areas; could interfere with other waterbody uses.

**REFERENCES:**

Lawler, Matusky & Skelly Engineers, "Lovett Generating Station Gunderboom Evaluation Program - 1995" Prepared for Orange and Rockland Utilities, Inc. Pearl River, New York, June 1996.

Lawler, Matusky & Skelly Engineers, "Lovett Generating Station Gunderboom System Evaluation Program - 1998" Prepared for Orange and Rockland Utilities, Inc. Pearl River, New York, December 1998.



Lawler, Matusky & Skelly Engineers, " Lovett Gunderboom Fabric Ichthyoplankton Bench Scale Testing" Southern Energy Lovett. New York, November 1999.

Lawler, Matusky & Skelly Engineers, "Lovett 2000 Report" Prepared for Orange and Rockland Utilities, Inc. Pearl River, New York, 2000.

<b>Fish Diversion or Avoidance Systems</b>	<b>Fact Sheet No. 12: Sound Barriers</b>
--	--

**DESCRIPTION:**

Sound barriers are non-contact barriers that rely on mechanical or electronic equipment that generates various sound patterns to elicit avoidance responses in fish. Acoustic barriers are used to deter fish from entering industrial water intakes and power plant turbines. Historically, the most widely-used acoustical barrier is a pneumatic air gun or "popper." The pneumatic air gun is a modified seismic device which produces high-amplitude, low-frequency sounds to exclude fish. Closely related devices include "fishdrones" and "fishpulsers" (also called "hammers"). The fishdrone produces a wider range of sound frequencies and amplitudes than the popper. The fishpulsar produces a repetitive sharp hammering sound of low-frequency and high-amplitude. Both instruments have had limited effectiveness in the field (EPRI, 1995; EPRI, 1989; Hanson, et al., 1977; EPA, 1976; Taft, et al., 1988; ASCE, 1992).

Researchers have generally been unable to demonstrate or apply acoustic barriers as fish deterrents, even though fish studies showed that fish respond to sound, because the response varies as a function of fish species, age, and size as well as environmental factors at specific locations. Fish may also acclimate to the sound patterns used (EPA, 1976; Taft et al., 1988; EPRI, 1995; Ray et al., 1976; Hadderingh, 1979; Hanson et al., 1977; ASCE, 1982).

Since about 1989, the application of highly refined sound generation equipment originally developed for military use (e.g., sonar in submarines) has greatly advanced acoustic barrier technology. This technology has the ability to generate a wide array of frequencies, patterns, and volumes, which are monitored and controlled by computer. Video and computer monitoring provide immediate feedback on the effectiveness of an experimental sound pattern at a given location. In a particular environment, background sounds can be accounted for, target fish species or fish populations can quickly be characterized, and the most effective sound pattern can be selected (Menezes, et al., 1991; Sonalysts, Inc.).

**TESTING FACILITIES AND/OR FACILITIES WITH TECHNOLOGY IN USE:**

No fishpulsers and pneumatic air guns are currently in use at power plant water intakes.

Research facilities that have completed studies or have on-going testing involving fishpulsers or pneumatic air guns include the Ludington Storage Plant on Lake Michigan; Nova Scotia Power; the Hells Gate Hydroelectric Station on the Black River; the Annapolis Generating Station on the Bay of Fundy; Ontario Hydro's Pickering Nuclear Generating station; the Roseton Generating Station in New York; the Seton Hydroelectric Station in British Columbia; the Surry Power Plant in Virginia; the Indian Point Nuclear Generating Station Unit 3 in New York; and the U.S. Army Corps of Engineers on the Savannah River (EPRI, 1985; EPRI, 1989; EPRI, 1988; and Taft, et al., 1998).

Updated acoustic technology developed by Sonalysts, Inc. has been applied at the James A. Fitzpatrick Nuclear Power Plant in New York on Lake Ontario; the Vernon Hydroelectric plant on the Connecticut River (New England Power Company, 1993; Menezes, et al., 1991; personal communication with Sonalysts, Inc., by SAIC, 1993); and in a quarry in Verplank, New York (Dunning, et al., 1993).

#### **RESEARCH/OPERATION FINDINGS:**

- C Most pre-1976 research was related to fish response to sound rather than on field applications of sound barriers (EPA, 1976; Ray et al., 1976; Uziel, 1980; Hanson, et al., 1977).
- C Before 1986, no acoustic barriers were deemed reliable for field use. Since 1986, several facilities have tried to use pneumatic poppers with limited successes. Even in combination with light barriers and air bubble barriers, poppers and fishpulsers, were ineffective for most intakes (Taft and Downing, 1988; EPRI, 1985; Patrick, et al., 1988; EPRI, 1989; EPRI, 1988; Taft, et al., 1988; McKinley and Patrick, 1998; Chow, 1981).
- C A 1991 full-scale 4-month demonstration at the James A. FitzPatrick (JAF) Nuclear Power Plant in New York on Lake Ontario showed that the Sonalysts, Inc. FishStartle System reduced alewife impingement by 97 percent as compared to a control power plant located 1 mile away. (Ross, et al., 1993; Menezes, et al., 1991). JAF experienced a 96 percent reduction compared to fish impingement when the acoustic system was not in use. A 1993 3-month test of the system at JAF was reported to be successful, i.e., 85 percent reduction in alewife impingement. (Menezes, et al., 1991; EPRI, 1999).
- C In tests at the Pickering Station in Ontario, poppers were found to be effective in reducing alewife impingement and entrainment by 73 percent in 1985 and 76 percent in 1986. No benefits were observed for rainbow smelt and gizzard shad. Sound provided little or no deterrence for any species at the Roseton Generating Station in New York.

- C During marine construction of Boston's third Harbor Tunnel in 1992, the Sonalysts, Inc. FishStartle System was used to prevent shad, blueback herring, and alewives from entering underwater blasting areas during the fishes' annual spring migration. The portable system was used prior to each blast to temporarily deter fish and allow periods of blasting as necessary for the construction of the tunnel (personal communication to SAIC from M. Curtin, Sonalysts, Inc., September 17, 1993).
- C In fall 1992, the Sonalysts, Inc. FishStartle System was tested in a series of experiments conducted at the Vernon Hydroelectric plant on the Connecticut River. Caged juvenile shad were exposed to various acoustical signals to see which signals elicited the strongest reactions. Successful in situ tests involved applying the signals with a transducer system to divert juvenile shad from the forebay to a bypass pipe. Shad exhibited consistent avoidance reactions to the signals and did not show evidence of acclimation to the source (New England Power Company, 1993).

#### **DESIGN CONSIDERATIONS:**

- C Sonalysts Inc.'s FishStartle system uses frequencies between 15 hertz to 130 kilohertz at sound pressure levels ranging from 130 to 206+ decibels referenced to one micropascal (dB/uPa). To develop a site-specific FishStartle program, a test program using frequencies in the low frequency portion of the spectrum between 25 and 3300 hertz were used. Fish species tested by Sonalysts, Inc. include white perch, striped bass, atlantic tomcod, spottail shiner, and golden shiner (Menezes et al., 1991).
- C Sonalysts' FishStartle system used fixed programming contained on Erasable Programmable Read Only Memory (EPROM) micro circuitry. For field applications, a system was developed using IBM PC compatible software. Sonalysts' FishStartle system includes a power source, power amplifiers, computer controls and analyzer in a control room, all of which are connected to a noise hydrophone in the water. The system also uses a television monitor and camera controller that is linked to an underwater light and camera to count fish and evaluate their behavior.
- C One Sonalysts, Inc. system has transducers placed 5 m from the bar rack of the intake.
- C At the Seton Hydroelectric Station in British Columbia, the distance from the water intake to the fishpulser was 350 m (1150 ft); at Hells Gate, a fishpulser was installed at a distance of 500 feet from the intake.
- C The pneumatic gun evaluated at the Roseton intake had a 16.4 cubic cm (1.0 cubic inch) chamber connected by a high pressure hose and pipe assembly to an Air Power Supply Model APS-F2-25 air compressor. The pressure used was a line pressure of 20.7 MPa (3000 psi) (EPRI, 1988).

#### **ADVANTAGES:**

- C The pneumatic air gun, hammer, and fishpulser are easily implemented at low costs.

- C Behavioral barriers do not require physical handling of the fish.

**LIMITATIONS:**

- C The pneumatic air gun, hammer, and fishpulser are not considered reliable.
- C Sophisticated acoustic sound generating system require relatively expensive systems, including cameras, sound generating systems, and control systems. No cost information is available since a permanent system has yet to be installed.
- C Sound barrier systems require site-specific designs consisting of relatively high technology equipment that must be maintained at the site.

**REFERENCES:**

ASCE. Design of Water Intake Structures for Fish Protection. American Society of Civil Engineers. New York, NY. 1982. pp. 69-73.

Chow, W., Isbwar P. Murarka, Robert W. Brocksen. Electric Power Research Institute, Entrainment and Impingement in Power Plant Cooling Systems. June 1981.

Dunning, D.J., Q.E. Ross, P. Geoghegan, J.J. Reichle, J. K. Menezes, and J.K. Watson. Alewives Avoid High Frequency Sound. 1993.

Electric Power Research Institute (EPRI). Fish Protection at Cooling Water Intakes: Status Report. 1999.

EPRI. Field Testing of Behavioral Barriers for Fish Exclusion at Cooling Water Intake Sytems: Ontario Hydro Pickering Nuclear Generating Station. Electric Power Research Institute. March 1989a.

EPRI. Intake Technologies: Research S . Prepared by Lawler, Matusky & Skelly Engineers, Pearl River, for Electric Power Research Institute. EPRI GS-6293. March 1989.

EPRI. Field Testing of Behavioral Barriers for Fish Exclusion at Cooling Water Intake Systems: Central Hudson Gas and Electric CoMany. Roseton Generating Statoni . Electric Power Research Institute. September 1988.

EPRI. Intake Research Facilities Manual. 1985. Prepared by Lawler, Matusky & Skelly Enginem, Pearl River, for Electric Power Research Institute. EPRI CS-3976. May 1985.

Hadderingh, R. H. "Fish Intake Mortality at Power Stations: The Problem and Its Remedy." Netherlands Hydrobiological Bulletin , 13(2-3), 83-93, 1979.

Hanson, C. H., J.R. White, and H.W. Li. "Entrapment and Impingement of Fishes by Power Plant

Cooling Water Intakes: An Overview." from Fisheries Review, MFR Paper 1266. October 1977.

McKinley, R.S. and P.H. Patrick. 'Use of Behavioral Stimuli to Divert Sockeye Salmon Smolts at the Seton Hydro-Electric Station, British Columbia." In the Electric Power Research Institute Proceedings Fish Protection at Steam and Hydroelectric Power Plants. March 1988.

Menezes, Stephen W. Dolat, Gary W. T'iller, and Peter J. Dolan. Sonalysts, Inc. Waterford, Connecticut. The Electronic FishStartle System. 1991.

New England Power Company. Effect of Ensonification on Juvenile American Shad Movement and Behavior at Vernon Hydroelectric Station, 1992. March 1993.

Patrick, P.H., R.S. McKinley, and W.C. Micheletti. "Field Testing of Behavioral Barriers for Cooling Water Intake Structures-Test Site 1-Pickering Nuclear Generating Station, 1985/96.\* In the Electric Power Research Institute Proceedings Fish Protection at Steam and Hydroelectric Power Plants. March 1988.

Personal Communication, September 17, 1993, letter and enclosure from MJ. Curtin (Sonalysts, Inc.) to D. Benelmouffok (SAIC).

Ray, S.S., R.L. Snipes, and D. A Tomljanovich. \*A State-of-the-Art Report on Intake Technologies.- TVA PRS-16 and EPA 600/6-76-020. October 1976.

Sonalysts, Inc. "FishStartle System in Action: Acoustic Solutions to Environmental Problems" (on video tape). 215 Parkway North, Waterford, CT 06385.

Taft, E. P., and J.K. Downing. -Comparative Assessment of Fish Protection Alternatives for Fossil and Hydroelectric Facilities.' In the Electric Power Research Institute Proceedings on Fish Protection at Steam and Hydroelectric Power Plants. March 1988.

Taft, E.P, J. K. Downing, and C. W. Sullivan. "Laboratory and Field Evaluations of Fish Protection Systems for Use at Hydroelectric Plants Study Update." In the Electric Power Research Institute's Proceedings: Fish Protection at Steam and Hydroelectric Power Plants. March 1988.

U.S. EPA. Development Document for Best Technology Available for the Location, Design, Construction, and Capacity of Cooling Water Intake Structures for Minimizing Adverse Environmental Impact. U.S. Environmental Protection Agency, Effluent Guidelines Division, Office of Water and Hazardous Materials. April 1976.

Uziel, Mary S., "Entrainment and Impingement at Cooling Water Intakes." Journal WPCF, Vol. 52, No.6. June 1980.

#### **ADDITIONAL REFERENCES:**

Blaxter, J.H'.S., and D.E. Hoss. "Startle Response in Herring: the Effect of Sound Stimulus Frequency, Size of Fish and Selective Interference with the Acoustical-lateralis System. " Journal of

the Marine Biological Association of the United Kingdom. 61:971-879. 1981.

Blaxter, J.J.S., J.A.B. Gray, and E.J. Denton. "Sound and Startle Response in Herring Shoals." J. Mar. Biol. Ass. U.K. 61:851-869. 1981.

Burdic, W.S. Underwater Acoustic System Analysis. Englewood Cliffs, New Jersey: PrenticeHall. 1984.

Burner, C.J., and H.L. Moore. "Attempts to Guide Small Fish with Underwater Sound." U.S. Fish and Wildlife Service. Special Scientific Report: Fisheries No. 403. 1962. p. 29.

C.H. Hocutt. "Behavioral Barriers and Guidance Systems." In Power Plants: Effects on Fish and Shellfish Behavior. C.H. Hocutt, J.R. Stauffer, Jr., J. Edinger, L. Hall, Jr., and R. Morgan, II (Editors). Academic Press. New York, NY. 1980. pp. 183-205.

Empire State Electric Energy Research Corporation. "Alternative Fish Protective Techniques: Pneumatic Guns and Rope. Nets." EP-83-12. March 1984.

Fay, R.R. Hearing in Invertebrates\* A Psych2-hysics Data Boo. HUI-Fay Associates. Winnetka, Illinois. 1988.

Frizzell, L.A., \*Biological Effects of Acoustic Cavitation." In Ultrasound Its Chemical, Physical and Biological Effects. K.S. Suslick (Editor). VCH Publishers, Inc. New York. 1988. pp. 297-319.

Haymes, G.T., and P.H. Patrick. "Exclusion of Adult Alewife (*Alosa pseudoharengus*), Using Low-Frequency Sound for Application of Water Intakes." Can. J. Fish. Aamatics Srd. 43:855862. 1986.

Micheletti, Coal Combustion Systems Division. "Fish Protection at Cooling Water Intake Systems." EM Journal. September 1987.

Micheletti, Coal Combustion Systems Division. wFish Protection at Cooling Water Intake Systems." EPRI Journal. September 1997.

Patrick, P.H., R.S. McKinley, A. E. Christie, and J.G. Holsapple. "Fish Protection: Sonic Deterrents." In the EPRI Proceeding: Fish Protection at Steam and Hydroelectric Power Plants. March 1988.

Platt, C., and A.N. Popper. "Find Structure and Function of the Ear." In Hearing and Sound Communication in Fishes. W.N. Tavolga, A.N. Popper and R.R. Ray (Editors). SpringerVerlag. New York.

Ross, Q.E., D. J. Dunning, R. Thorne, J. Menezes, G. W. Tiller, and J. K. Watson. Response of Alewives to High Frequency Sound at a Power Plant Intake on Lake Ontario. 1993.

Schwarz, A.L., and G.L. Greer. "Responses, of Pacific Herring, *Cluttea harengus* Rallasi, to Some

Undervrater Sounds." Can. J. Fish, Aquatic Sci. 41:1193-1192. 1984.

Smith, E.J., and J.K. Andersen. "Attempts to Alleviate Fish Losses from Allegheny Reservoir, Pennsylvania and New York, Using Acoustic." North American Journal of Fisheries Management vol 4(3), 1994. pp. 300-307.

Thorne, R.E. "Assessment of Population Density by Hydroacoustics." In Journal of Biological Oceanography. Vol. 2. 1983. pp. 252-262.